



Safety & Buildings Division
201 West Washington Avenue
P.O. Box 2658
Madison, WI 53701-2658

Evaluation #

200265-H

Wisconsin Building Product Evaluation

Unit Heaters:

Manufacturer: Thomas & Betts Corporation, Reznor Div.
150 McKinley Ave.
Mercer, PA 16137

Approved Product(s): Trade Name: **Reznor V3 Series**

Model Numbers: UDAP 30, 45, 60, 75, 100, 125, 150, 175,
200, 225, 250, 300, 350, & 400.

UDAS 30, 45, 60, 75, 100, 125, 150, 175,
200, 225, 250, 300, 350, & 400.

SCOPE OF EVALUATION: This review includes the cited:
Comm code requirements in accordance with the current
**Wisconsin Dwelling Code (UDC); International Building
Code (IBC); International Mechanical Code (IMC); and
International Fuel Gas Code (IFGC).**

TESTS: The unit heaters were tested in accordance with ANSI Z83.8b Standard for Gas Unit Heaters and Gas-Fired Duct Furnaces, and CSA International 10.96 US Standard for Unit Heater for Residential Use. The equipment is listed and certified by CSA International.

LIMITATIONS OF APPROVAL: The unit heaters shall be installed as allowed in **s. Comm 23.04** of the **UDC**; **s. IBC 302.1**; **ss. IMC 301, 303, and 920**; **s. IFGC 619**, their listing and the manufacturer's recommendations.

Suspended equipment shall also be installed as allowed by the particular occupancy chapter.

This approval will be valid through December 31, 2007, unless manufacturing modifications are made to the product or a re-examination is deemed necessary by the department.

The Wisconsin Building Products Evaluation number must be provided when plans that include this product are submitted for review.

DISCLAIMER: The department is in no way endorsing or advertising this product. This approval addresses only the specified applications for the product and does not waive any code requirement not specified in this document.

Revision Date:

Approval Date: February 27, 2003 By: _____

Lee E. Finley, Jr.
Product/Material &
Building Plan Review
Integrated Services Bureau

200265-H.doc